

NASSAU UNIVERISTY MEDICAL CENTER
2201 HEMPSTEAD TURNPIKE, EAST MEDOW, NY 11554
LEA PROJECT NO. 6684

NOTE: *The following addendum includes responses to bidders questions and modifications to contract documents prior to bid date. Bidders should review all questions and responses, and incorporated requirements into their bids. All Requirements of the original Specifications and Drawings shall remain in force except as amended by this ADDENDUM. This addendum forms a part of the contract documents for the above project and must be acknowledged in the plans and specifications. Attach it to the inside front cover of each of the specifications.*

ALL CONTRACTS

REVISIONS TO CONTRACT DOCUMENTS

1. Who is the existing fire alarm vendor?
Simplex-Grinnell is the existing fire alarm vendor. All new devices shall be compatible with existing base building fire alarm system. For additional information contact Kevin Quigley at: kevin.quigley@jci.com or 631.404.1013.
2. Also where will the new fire alarm devices be tied into the existing system? For instance a data gathering panel or control panel location.
New devices shall be connected to existing terminal cabinet and fire alarm control panel in elevator lobby indicated on the RFI 01 attachments.

END OF RFI NO. 1

S:\6684\DOCUMENTS\MISCELLANEOUS\RFIS\RFI 01\RFI 01 - FIRE ALARM_RESPONSE.DOC